

ADDENDUM #2

Commission No. 19590

PRAIRIE ENGINEERING, P.C.
619 RIVERWOOD DRIVE, SUITE 205
BISMARCK, NORTH DAKOTA 58504

THIS ADDENDUM SHALL BECOME A PART OF THE PLANS AND SPECIFICATIONS AND ITS RECEIPT SHALL BE NOTED ON THE BID FORM.

DRAWING ITEM #1: Drawing Sheet E1.0 – MOTOR & EQUIPMENT SCHEDULE

Disconnect for electric boiler B-5 to be 800/3 FDS in lieu of 600/3 FDS. Conductors for boiler B-5 to have a required ampacity of 800 Amperes.

END OF ADDENDUM #2